

Summary Report



Cable Label	Limit	Result	Length (m)	Margin (dB)	Date & Time
FB-001	ISO 14763-3		3.1	0.48	11/3/2018 1:23:00 PM
SE-05	ISO - Class FA Channel		57.2	6.5	11/17/2018 3:03:00 PM
SE-08	TIA - Cat 6A Channel		24.4	9.3	3/7/2019 12:22:09 PM
SE-09	TIA - Cat 6 Channel		18.5	4.4	3/7/2019 12:26:00 PM
SE-10	TIA - Cat 5e Channel		25.5	10.4	3/7/2019 12:27:49 PM
SE-11	TIA - Cat 5e Channel		64.3	12.9	3/7/2019 12:28:43 PM
SE-12	TIA - Cat 6A Permanent Link		67.4	14.7	3/7/2019 12:34:20 PM
FB-002	TIA-568.3		244	0.5	11/30/2018 5:46:00 PM
MP-01	40GBASE-SR4		0	-	11/18/2018 2:26:00 PM
SE-07	TIA - Cat 8 Channel 22-23AWG		31.1	13.8	10/31/2018 11:43:00 PM

Total for Selected Reports	Pass	Fail	Length (m)
Copper	7	0	288.4
Fiber	2	0	247.1
MPO	1	0	0